


# Maine Technical Services LLC

8283 Seneca Turnpike  
Clinton, New York 13323  
(315) 272-7959

## Infrared Thermography Report



<b>Customer</b>	
<b>Location</b>	
<b>Equipment</b>	34.5 KV STRUCTURE



<b>Level of Severity</b>	1 HIGH
--------------------------	--------

<b>IR information</b>	<b>Value</b>
Date of creation	11/16/2009

<b>Label</b>	<b>Value</b>
SP01	157.8°F
SP02	88.9°F
SP03	59.6°F

### Recommendation

These connections need to be inspected