



Maine Technical Services LLC

8283 Seneca Turnpike
Clinton, New York 13323
(315) 272-7959

Infrared Thermography Report



Customer	
Location	
Equipment	34.5 KV STRUCTURE



Level of Severity	1 HIGH
--------------------------	--------

IR information	Value
Date of creation	11/17/2009

Label	Value
SP01	122.6°F
SP02	121.9°F
SP03	46.2°F

Recommendation

These connections need to be inspected